

Hours	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	Total	AVG/MW		
East																												
100 MW Power Plant	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
Asadabad (Kunar)																											5.7	0.2
Darunta	7.8	8.7	8.6	8.6	8.1	5.9	7.3	7.4	7.3	7.2	7.3	7.5	7.1	7.2	4.6	7.3	7.2	7.0	7.3	7.3	7.2	7.2	7.3	7.3	7.3	175.7	7.3	
Ghazni																											5.3	0.2
Kbi-Surobi	21.5	21.5	21.5	21.5	21.5	21.5	21.5	21.5	21.5	21.5	21.5	21.5	21.5	21.5	21.5	21.5	21.5	21.5	21.5	21.5	21.5	21.5	21.5	21.5	21.5	516.0	21.5	
Khost																											6.9	0.3
Mahipar	0.0	0.0	0.0	0.0	0.0	0.0	10.0	10.0	10.0	10.0	0.0	0.0	10.0	10.0	0.0	0.0	10.0	10.0	10.0	12.0	0.0	0.0	0.0	0.0	0.0	102.0	4.3	
Nagflu	20.0	22.0	40.0	26.0	22.0	22.0	22.0	22.0	34.0	38.0	44.0	44.0	40.0	38.0	46.0	46.0	48.0	50.0	50.0	50.0	50.0	42.0	32.0	27.0	875.0	36.5		
NEPS Line	45.5	48.0	65.5	65.5	55.5	47.0	55.0	59.0	70.0	68.0	65.0	65.0	65.0	67.0	70.0	82.0	88.0	84.0	86.0	98.0	75.0	60.0	50.0	1599.0	66.6			
NW Kabul 3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
NW Kabul 4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
NWK Frame 5's	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
Hourly Total	94.8	100.2	135.6	121.6	107.1	96.4	115.8	119.9	142.8	144.7	137.8	138.0	143.6	141.7	139.1	144.8	168.7	176.5	172.8	176.8	176.7	145.7	120.8	105.8	3,285.5	136.9		

Hours	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	Total	AVG/MW		
North																												
Andkhoy	1.8	1.8	3.6	1.8	1.8	1.8	1.8	3.6	3.6	3.6	3.6	3.6	3.6	1.8	1.8	1.8	1.8	1.8	3.6	5.4	5.4	3.6	1.8	1.8	66.6	2.8		
Aybak (Samangan 2)	0.6	0.7	1.3	0.8	0.5	0.5	0.7	1.0	1.0	1.0	1.1	1.0	1.0	0.5	1.0	1.2	1.5	2.0	1.6	1.9	1.9	1.4	0.9	0.6	25.7	1.1		
Baghlan (City)	2.1	2.3	2.6	2.2	2.0	2.0	1.8	2.2	2.6	2.6	2.9	4.8	3.1	3.2	3.2	3.4	4.8	3.0	3.6	3.7	3.2	2.6	2.2	2.2	70.8	3.0		
Charikar																										14.0	0.6	
Charikar 2																										14.8	0.6	
Ghurband	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	1.2	0.0	
Istalf																												
Jabal-u-Saraj	0.3	0.3	0.3	0.3	0.3	0.3	0.0	0.0	0.0	0.0	0.0	0.0	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	5.4	0.2	
Khojadako																										9.7	0.4	
Kunduz	9.0	11.0	9.0	8.0	8.0	8.0	9.0	10.0	9.0	9.0	9.0	9.0	9.0	11.0	11.0	12.0	12.0	12.0	14.0	15.0	15.0	12.0	10.0	9.0	250.0	10.4		
Maymana																										168.0	7.0	
Mazar-e-Sharif	24.0	24.0	24.0	26.0	24.0	24.0	24.0	26.0	26.0	21.0	26.0	27.0	27.0	28.0	26.0	24.0	26.0	21.0	24.0	28.0	27.0	28.0	26.0	24.0	605.0	25.2		
Pul-e-Khomri (2)	5.6	5.8	4.6	3.5	3.6	3.6	5.7	6.0	5.7	5.2	5.1	3.0	4.4	4.5	5.4	5.4	6.8	1.8	5.8	5.8	6.0	5.2	4.8	4.6	117.9	4.9		
Sar-e-Pul	0.7	0.7	1.0	1.0	1.0	0.7	0.7	1.0	1.0	0.7	0.7	1.0	1.2	1.0	1.0	1.2	1.0	1.2	1.4	1.4	1.7	1.0	1.2	0.7	24.0	1.0		
Sheberghan	6.7	8.8	6.7	8.8	8.8	6.7	6.7	6.7	6.7	8.8	8.8	8.8	8.8	6.7	8.8	6.7	6.7	11.0	8.9	8.8	6.7	8.8	8.6	6.5	189.2	7.9		
Hourly Total	50.9	55.4	53.0	52.3	50.0	47.6	50.4	56.4	55.5	52.0	57.2	58.1	58.4	56.9	58.5	56.0	60.9	55.9	62.8	70.2	67.7	63.5	56.2	49.8	1,562.3	65.1		

Hours	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	Total	AVG/MW		
South																												
Grishk	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1	1.1	27.0	1.1	
Kajaki 1																												
Kajaki 3																												
Kandahar Agrekko	4.5	4.3	5.5	5.4	4.6	3.5	3.4	5.1	4.2	4.2	4.2	5.8	6.2	6.2	6.3	6.3	5.5	6.3	6.9	6.3	6.1	3.9	5.3	4.7	124.8	5.2		
Kandahar QSK60	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
Lashkar-Gah (Helmand)	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
Paktya																										1.6	0.1	
Qalat	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.9	0.9	0.8	0.8	0.7	1.0	1.1	1.1	1.0	0.7	0.6	0.6	0.6	10.6	0.4		
Tirin Kot (Uruzgan)																										1.3	0.1	
Hourly Total	5.7	5.5	6.6	6.5	5.8	4.6	4.5	6.2	5.3	5.4	5.4	7.8	8.2	8.1	8.2	8.1	7.5	8.6	9.1	8.4	8.0	5.6	7.0	6.4	165.2	6.9		

Hours	1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	Total	AVG/MW		
West																												
Herat (Iran)	24.0	23.0	26.2	28.6	25.4	20.0	24.6	30.8	32.2	32.8	34.2	23.8	31.6	32.0	32.6	36.0	41.8	37.6	42.2	42.8	43.0	38.8	33.8	26.4	764.2	31.8		
Herat (Turkmenistan)	15.0	15.0	17.0	18.5	17.0	16.5	16.0	16.5	17.5	17.5	17.5	18.5	18.5	18.0	18.0	19.0	20.0	21.0	19.5	17.5	17.5	19.0	18.0	16.5	425.0	17.7		
Herat Ghorian (Iran)	6.0	6.1	9.9	7.7	7.7	5.6	6.8	7.2	6.8	7.9	7.5	7.4	7.3	7.4	7.5	7.7	10.0	13.0	12.2	12.0	12.6	9.7	5.9	5.0	196.9	8.2		
Zaranj (Iran)																										162.8	6.8	
Hourly Total	45.0	44.1	53.1	54.8	50.1	42.1	47.4	54.5	56.5	58.2	59.2	49.7	57.4	57.4	58.1	62.7	71.8	71.6	73.9	72.3	73.1	67.5	57.7	47.9	1,548.9	64.5		

Daily Grand Total MWH

6,562.0 273.4

Daily percentage of MWH based on data provided:

Hydro 28.0 % Thermal 2.29 % Import 69.7 %

Note: Zero indicates no production. Blank cells indicate missing or incomplete data.

Source of Data: DABS and Operating Plants

Prepared by: - Haris Farhad

All totals and calculations are based only on available data