

Hours		1:00	2:00	3:00	4:00	5:00	6:00	7:00	8:00	9:00	10:00	11:00	12:00	13:00	14:00	15:00	16:00	17:00	18:00	19:00	20:00	21:00	22:00	23:00	24:00	Total	AVG/MW	
East																												
100 MW Power Plant	Thermal	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	16.0	17.0	17.0	16.0	14.0	0.0	0.0	80.0	3.3	
Asadabad (Kunar)	Hydro																										5.3	0.2
Darunta	Hydro	3.3	3.4	3.4	3.4	4.6	3.6	3.1	2.7	3.0	3.6	3.6	3.4	3.0	3.8	2.8	3.6	4.5	7.5	7.6	6.6	6.2	2.9	2.8	3.2	95.6	4.0	
Istaf	Hydro																										0.9	0.0
Kbl-Surobi	Hydro	14.0	14.0	14.0	14.0	14.0	22.0	14.0	14.0	14.0	14.0	14.0	14.0	14.0	14.0	14.0	14.0	16.0	22.0	22.0	22.0	22.0	22.0	22.0	22.0	402.0	16.8	
Mahipar	Hydro	28.0	28.0	28.0	28.0	30.0	32.0	28.0	28.0	30.0	27.0	27.0	25.0	27.0	25.0	25.0	29.0	31.0	31.0	31.0	29.0	26.0	26.0	29.0	31.0	679.0	28.3	
Naghlu	Hydro	18.0	15.0	16.0	17.0	17.0	17.0	17.0	17.0	17.0	17.0	18.0	17.0	18.0	18.0	18.0	18.0	18.0	18.0	18.0	18.0	18.0	18.0	18.0	18.0	16.0	417.0	17.4
NEPS Line	Import	200.0	199.0	198.0	199.0	198.0	222.0	242.0	255.0	250.0	250.0	255.0	230.0	230.0	224.0	236.0	250.0	240.0	240.0	258.0	266.0	240.0	240.0	236.0	200.0	5558.0	231.6	
NW Kabul 3	Thermal	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0			
NW Kabul 4	Thermal	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
NWK Frame 5's	Thermal	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0		
Hourly Total		263.3	259.4	259.4	261.4	263.6	296.6	304.1	316.7	314.0	311.6	317.6	289.4	292.0	284.8	295.8	314.6	309.5	334.5	353.6	358.6	328.2	322.9	307.8	272.2	7,237.8	301.6	
North																												
Andkhoy	Import	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6	1.8	1.8	1.8	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6	3.6	81.0	3.4	
Aybak (Samangan 2)	Import	1.5	1.5	1.6	1.6	1.7	2.2	2.6	2.4	2.2	2.1	2.2	2.1	2.2	1.9	1.9	2.1	2.4	2.6	2.4	2.5	2.4	2.2	2.1	1.1	49.6	2.1	
Baghlan F (1) (5) (6)	Import	8.2	6.8	6.9	6.9	7.2	6.7	7.3	7.2	6.7	9.0	8.8	7.4	3.9	7.1	7.9	6.5	6.9	7.7	7.6	8.3	8.2	7.8	7.2	7.3	175.6	7.3	
Charikar	Hydro																									0.4	0.0	
Ghurband	Hydro	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	1.2	0.0	
Jabal-u-Saraj	Hydro	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.1	0.0	0.0	1.5	0.1	
Khojadako	Import																									9.0	0.4	
Kunduz	Import	13.0	13.0	13.0	14.0	15.0	17.0	16.0	16.0	16.0	16.0	16.0	16.0	16.0	16.0	19.0	18.0	20.0	19.0	19.0	19.0	19.0	19.0	12.0	12.0	12.0	382.0	15.9
Maymana	Import																									196.0	8.2	
Mazar-e-Sharif	Import	39.0	38.0	38.0	38.0	37.0	35.0	38.0	36.0	37.0	38.0	31.0	36.0	35.0	35.0	37.0	39.0	38.0	31.0	39.0	41.0	41.0	41.0	40.0	41.0	899.0	37.5	
Pul-e-Khomri (2)	Hydro	2.5	2.5	9.0	9.0	1.0	3.0	2.8	3.0	3.0	2.9	2.9	2.8	2.8	2.7	2.6	1.2	1.2	2.7	4.0	4.0	4.1	2.9	2.9	2.5	78.0	3.3	
Sar-e-Pul	Import	1.2	1.0	1.0	1.2	1.2	1.7	1.4	1.4	1.2	1.2	1.4	1.7	1.7	1.4	0.0	0.0	0.7	1.4	1.4	1.7	1.4	1.7	1.4	1.7	30.2	1.3	
Sheberghan	Import	6.5	6.5	6.3	6.5	8.4	6.5	4.4	4.4	4.4	4.4	4.4	4.4	4.4	4.4	6.5	6.5	6.5	4.4	6.5	4.4	4.4	6.5	6.5	6.3	8.6	138.2	5.8
Hourly Total		75.6	72.9	79.3	80.9	75.2	75.8	76.1	74.1	74.2	77.3	70.5	74.2	69.7	72.7	76.8	75.2	77.4	74.7	81.6	84.5	86.3	77.8	75.5	77.8	2,041.7	85.1	
South																												
Ghazni	Thermal																										7.1	0.3
Grishk	Hydro	1.3	1.3	1.3	1.3	1.3	1.3	1.3	1.3	1.3	1.3	1.3	1.3	1.3	1.3	1.3	1.3	1.3	1.3	1.3	1.3	1.3	1.3	1.3	1.3	30.0	1.3	
Kajaki 1	Hydro	11.0	12.0	12.0	14.0	13.0	9.0	11.0	10.0	10.0	6.0	12.0	9.0	8.0	12.0	7.0	7.0	14.0	10.0	12.0	12.0	11.0	12.0	13.0	12.0	259.0	10.8	
Kajaki 3	Hydro	15.0	11.0	10.0	12.0	12.0	9.0	10.0	9.0	9.0	6.0	12.0	6.0	5.0	11.0	7.0	7.0	0.0	0.0	11.0	11.0	11.0	12.0	12.0	11.0	219.0	9.1	
Kandahar Agrekko	Thermal																											
Kandahar QSK60	Thermal																											
Khost	Thermal																										4.7	0.2
Lashkar-Gah (Helmand)	Thermal	0.6	0.6	0.6	0.6	0.6	0.6	0.8	0.9	0.8	0.7	0.7	0.7	0.7	0.7	0.0	0.7	0.8	0.6	0.8	0.8	0.8	0.7	0.7	0.6	16.1	0.7	
Paktya	Thermal																										2.3	0.1
Qalat	Thermal																											
Tirin Kot (Uruzgan)	Thermal																										1.0	0.0
Hourly Total		27.9	24.9	23.9	27.9	26.8	19.8	23.1	21.1	21.1	14.0	25.9	17.0	14.9	25.0	15.3	15.9	16.0	11.8	25.0	25.0	24.0	25.9	26.9	24.9	539.2	22.5	
West																												
Herat (Iran)	Import	45.9	46.2	46.2	46.6	46.4	40.9	46.4	46.0	46.5	43.7	45.4	41.8	41.6	46.1	44.6	43.9	42.5	41.3	43.0	41.1	36.3	44.5	41.4	44.7	1053.0	43.9	
Herat (Turkmenistan)	Import	24.0	24.5	25.0	25.0	24.0	23.0	20.0	21.0	21.0	21.5	21.0	22.0	22.5	23.0	23.0	23.0	22.0	19.0	19.5	20.0	20.0	22.0	23.0	23.0	532.0	22.2	
Herat Ghorian (Iran)	Import	16.4	16.3	16.3	14.8	16.3	18.5	24.3	20.8	17.6	17.5	22.7	21.3	21.4	21.4	21.2	21.9	22.5	22.9	24.0	24.0	22.3	21.1	19.2	17.3	482.0	20.1	
Zaranj (Iran)	Import																										196.2	8.2
Hourly Total		86.3	87.0	87.5	86.4	86.7	82.4	90.7	87.8	85.1	82.7	89.1	85.1	85.5	90.5	88.8	88.8	87.0	83.2	86.5	85.1	78.6	87.6	83.6	85.0	2,263.2	94.3	

Daily Grand Total MWH

12,081.9 503.4

Daily percentage of MWH based on data provided:

Hydro 18.1% Thermal 0.92% Import 81%

Note: Zero indicates no production. Blank cells indicate missing or incomplete data.

Source of Data: DABS and Operating Plants

Prepared by: - Haris Farhad

All totals and calculations are based only on available data